

NOTICE OF ADOPTION OF
AMENDMENTS TO AN ORDINANCE
KNOWN AS THE SEWER USE ORDINANCE
OF THE TOWN OF ALLEGANY, NEW YORK

LEGAL NOTICE IS HEREBY GIVEN that pursuant to Section 130 of the Town Law of the State of New York, and following a Public Hearing held at the Town Hall, Main Street, Town of Allegany, on the 1st day of November, 1984 at 7.30 o'clock p.m. , the following resolution was duly adopted :

The Town Board of the Town of Allegany hereby resolves that certain amendments of the ordinance known as the "Sewer Use Ordinance of the Town of Allegany", heretofore adopted on the 1st day of November , 1984, be and the same are hereby adopted.

Following are the amendments to the "Sewer Use Ordinance of the Town of Allegany". The full context of the ordinance is on file in the Town Clerk's Office , Town Hall, Allegany, New York.

TOWN OF ALLEGANY, CATTARAUGUS COUNTY, NEW YORK

The Town of Allegany
Sewer Use Ordinance

Be it enacted by the Town Board of the Town of Allegany , New York as follows:

Sec. 5.4. Add this paragraph.

In the Case of mobile home courts, as many as twenty (20) units may be connected to one 6" building sewer, provided that it is demonstrated to the Town Board that proper engineering and hydraulic characteristics are met, and further provided that the building sewer remains privately owned.

Sec. 6.3 (d) Delete entire original section. Replace it with the following:

Any liquid or vapor having a temperature higher than one hundred fifty degrees (150°) F (65°C), or in such quantities that the temperature at the treatment works influent exceeds one hundred four (104°F), (40° C).

Sec. 6.3 (e) Delete entire original section. Replace it with the following:

Any water or waste containing fats, wax, grease, or oils, whether emulsified or not, in excess of fifty (50) mg/l or containing substances which may solidify or become viscous at temperatures between thirty-two (32) and one hundred four degrees (104°) F (0 and 40°C).

Sec. 6.3 (h) Delete entire original section. Replace it with the following:

Any waters or wastes containing heavy metals and similar objectionable or toxic substances to such degree that any such material received in the sewage at the point of discharge exceeds the limits established below:

<u>Parameter</u>	<u>Effluent Concentration Limits (mg/l)</u>	
	<u>30 Day Average</u>	<u>24 Hour Average</u>
Lead	0.2	0.4
Available Chlorine	50.0	50.0
Selenium	0.2	0.4
Sulfide	6.0	12.0
Barium	4.0	8.0
Manganese	4.0	8.0
Gold	0.2	0.4
Fluorides-to fresh water	4.0*	8.0*
Phenol	4.0	8.0

* May be multiplied by a factor of 1.5 if the municipal water supply is not fluoridated.

The following is required by the City of Olean:

	<u>24 Hour Composite</u>
Chromium, Hexavalent	5.5 mg/l
Copper (Total)	2.1 mg/l
Cadmium (Total)	1.0 mg/l
Cyanide (D)	0.2 mg/l
Zinc (Total)	20.0 mg/l
Nickel (Total)	0.9 mg/l
Arsenic (D)	0.02 mg/l
Lead (Total)	18.0 mg/l
Mercury (D)	0.7 mg/l
Silver (D)	10.2 mg/l
Trichlorethylene (D) - Dissolved	1.0 mg/l

Sec. 6.5 Delete entire original section. Replace it with the following:

Grease, oil, and sand interceptors shall be provided when, in the opinion of the Superintendent, they are necessary for the proper handling of liquid wastes containing grease in excessive amounts, or any flammable wastes, sand, or other harmful ingredients; except that such interceptors shall not be required for private living quarters or dwelling units. All interceptors shall be of a type and capacity approved by the Superintendent, and shall be located as to be readily and easily accessible for cleaning and inspection. The Superintendent shall require grease interceptors on all restaurants and food processing establishments. A periodic inspection of these interceptors shall be made by the Superintendent at least four (4) times per year.

The amendments to this ordinance shall take effect according to the provisions of Section 133 of the Town Law.

TOWN BOARD OF THE TOWN OF ALLEGANY

BY Carol G. Livingston
Carol G. Livingston, Town Clerk