

DPW REPORT January 5, 2004

- Worked on DPW equipment.
- Sanded streets and plowed snow as needed.
- Cleaned catch basins as needed.
- New Water Generator has been installed at Water Well House #2 – waiting on Company we purchased it from to come and put it in service.
- Pumps at Sewer Lift Stations are all currently working. Still working on a plan for up grading system and should have something for next meeting.
- Currently picking up X-Mas Trees left out in front of residences.
- Outside area near back shop was cleaned and hauled to the pit.
- Chipped up X-Mas Trees that have been picked up in Village.
- Hauling sand and mixing sand and salt to be put down on streets when needed.

DPW REPORT February 2, 2004

- Worked on DPW equipment and organized Shop areas.
- Sanded streets and plowed snow as needed.
- New Water Emergency Generator has been put into service.
- Sewer Lift Station #2 upgrade, approximate cost numbers are in a separate report for Mayor and Village Board members to review.
- Still picking up X-Mas Trees left out in front of residences.
- Hauling sand and mixing sand and salt to be put down on streets when needed. We have ordered our last load of salt at discount price. If more salt is needed in future we will be purchasing it at a higher price. I am hoping the stockpile we have now will last us the rest of the winter.
- Shoveled out snow from around fire hydrants in village.
- Shut off water to approximately six residences due to water lines and/or water meters freezing up.
- Hauled snow from various places in Village to area behind Firemen's Community Center to make room for future snow plowing of Village Streets.
- Sidewalk plow needed to be taken to Portville Truck to repair bolts that hold transfer case up to the transmission. Sidewalk plow has been fixed and is back in service.
- Sander spreader needed to have parts ordered for it so it could be repaired. Sander has been fixed and is working good.

DPW REPORT March 1, 2004

- Worked on DPW equipment – serviced vehicles etc.
- Sanded streets and plowed snow as needed.
- Took down X-Mas Decorations off Municipal Bldg
- Took down X-Mas Wreaths from light poles on Main Street. Wreaths will be stored in Basement at Municipal Bldg.
- Cleaned snow off subways in Business District area on Main Street and hauled snow from Fire Hall area. Town Highway assisted us with same. Snow was hauled to area behind the Firemen's Community Center.
- Chipped ice off of and cleaned top of storm sewer catch basins so melting snow and rain water can get into them.
- Currently sweeping sand and other debris off of village streets.
- Unplugged a sewer line on Constitution Ave for the Town.
- Assisted with a plugged sewer on South Seventh Street.
- Inspected Sewer and Water hook up at new house on East Main Street.
- Swept area around Municipal Bldg.
- Back Flow Testing has been completed in the Town and they are currently working on Village.
- Currently flushing sewers in village.
- Put down cold patch in pot holes on village streets.
- One of the gas tanks on the One-Ton Dump had a large leak – replaced the gas tank.
- Worked on Budget.
- Lance did Code as needed.

DPW REPORT April 5, 2004

- Sanded streets and plowed snow as needed.
- Made brackets to store wreaths in Basement at Municipal Bldg.
- Have been sweeping sand and other debris off of village streets.
- Swept area around Municipal Bldg.
- Flushed some sewers in village.
- Put down cold patch in pot holes on village streets.
- Worked on Budget.
- Dug up and replaced drain at Water Well House #1.
- Put new shut off valves in Water well House #1.
- Working on Clay valve in Water Well House #1.
- Cleaned tops of catch basins as needed.
- Started picking up brush and leaves put out at curbs.
- Worked on equipment as needed.
- Lance did Code as needed.

DPW REPORT May 3, 2004

- Sanded streets as needed.
- Swept sand off of all subways in village.
- Have been sweeping village streets.
- Flushed some sewers in village.
- Put down cold patch in pot holes on village streets.
- Cleaned tops of catch basins as needed.
- Picking up brush and leaves put out at curbs.
- Lance did Code as needed – Fire Inspections done at businesses.
- Cleaned junk from area near back shop.
- Read Water Meters for Quarter Billing.
- Worked on Clay Valve at Water Well House #2.
- Replaced Fire Hydrant & put in water valve in area near 103 North Fifth Street.
- Sander was taken off the 1992 International Dump Truck and the truck was taken to T-W to get new dump box put on.
- Prepared equipment for cutting grass and Cut grass as needed.
- New Street Name Signs and posts for same have been ordered (2003/2004 Budget).
- Cross-Walk and other street marking tape including tape for Municipal Bldg Parking Lot and adhesive for putting it down has been ordered (2003/2004 Budget).
- Trustee Gleason and Superintendent Papasergi have been looking into street sweepers and should have some recommendations and figures for the Board within the next couple of meetings.

DPW REPORT June 7, 2004

- Village streets have all been swept.
- Flushed some sewers in village.
- Currently putting down black-top where needed on various village streets.
- Cleaned tops of catch basins as needed.
- Picking up brush and leaves put out to curbs.
- Lance did Code as needed.
- 1992 International Dump Truck was taken to T-W to get new dump box put on. New box was put on and everything looks good.
- Cut grass as needed.
- New Street Name Signs and posts for same have arrived and will be put up in the near future.
- Street marking tape was put down in areas of no parking here to corner and areas of fire hydrants on Main Street, between First Street and Fifth Street. Warnings to be put on vehicles in these areas for a week and then better enforcement of same. So far violations have been minimal since tape was put down.
- Flag pole holder brackets and banner brackets have been put up on light poles on Main Street. American Legion Women's Auxiliary purchased flags and poles for same so they could be put up prior to Memorial Day.
- Brick Subways were hosed off on Main Street between First Street and Fifth Street. Fire Department hosed off subways and a member of the DPW Crew Swept up debris with Street Sweeper.
- Trustee Gleason and Superintendent Papasergi are still looking into street sweepers.
- Put down Top Soil in some areas of Village – Due to excessive amount of rain have not been able to get all areas needing top soil done yet, but as weather permits we will get other needed areas done.

DPW REPORT July 5, 2004

- Some village streets have been swept.
- Currently putting down black-top where needed on various village streets.
- Cleaned tops of catch basins as needed.
- Picked up brush and leaves put out to curbs. County is now taking yard waste at the Transfer Station on Union Street.
- Lance did Code as needed.
- Cut grass as needed.
- Some of the flag pole holder brackets and banner brackets have been taken back down by contractors of the State so that they can strip the light poles on Main Street and repaint them. The contractor wants us to take the rest of them down before they come back to strip and I advised that they had already agreed that they would take them down and put them back up. I was later contacted by them saying they couldn't keep their end of the agreement, after we already put them up. I advised that we were already giving them a lot by saying we would put them back up but that they should meet us halfway and at least take them down. Still waiting on what their plans are.
- Put down Top Soil in some areas of Village – Due to excessive amount of rain have not been able to get all areas needing top soil done yet, but as weather permits we will get other needed areas done.
- Put up temporary No Parking Signs on Pine Street and Elm Street for Firemen's annual Old Home Week Activities. Signs were also taken down after the event.
- Cut and Chipped trees and brush in storm water ponding area off of East Main Street near Emerald Hills Estates. Currently working on cleaning out ditches leading to area and have bulldozed some of the ponding area. Waiting for area to dry out a little so we can get in to make the drainage better. State officials met with us and are preparing a suggestion plan to go by to complete the project. State will do a curb cut on East Main St for accessibility to area.
- Trustee Gleason and Superintendent Papasergi have looked into street sweepers and made recommendation to Village Board.

DPW REPORT July 5, 2004 Continued

- Prepared and put out to bid the following:

Purchase of new Street Sweeper with hose attachment for cleaning Storm Sewers.

Sell the 1988 Street Sweeper.

Purchase three new 25HP solid waste sewer pumps for Sewer Lift Station #2.

Upgrade sewer pump rails and inflow baffles at Sewer Lift Station #2.

Curbing and Storm Sewer upgrades on Maple Ave between the area of North Fourth Street and the Elementary School playground parking lot driveway.

DPW REPORT August 2, 2004

- Some village streets have been swept.
- Cleaned tops of catch basins as needed.
- Cleaned some storm sewer catch basins in Village with new storm sewer cleaner.
- Picked up brush and leaves put out to curbs.
- Lance did Code as needed.
- Cut grass as needed.
- Put new Street Name Signs at all intersections in Village (except Main St area). Also put in No Parking This Side signs at N. Second and N. Third Streets where construction occurred last year.
- Still putting down Top Soil in some areas of Village – Due to excessive amount of rain have not been able to get all areas needing top soil done yet, but as weather permits we will get other needed areas done.
- Prepared Sherwood, Williams Jefferson and Clarence Streets to be resurfaced.
- Resurfaced Sherwood, Williams Jefferson and Clarence Streets.
- The Three Year Maintenance Work at Water Well House #1 was completed.
- Made a curb cut for driveway at new house built on N. Fifth Street.
- Worked on planting area - planted flowers and bushes in front of the Municipal Bldg.
- Redesigned gas line hooked up to new emergency generator at Water Well House #2 as per gas company request.
- Village Board accepted bid of \$107,500.00 from J&J Equipment for new Street Sweeper / Storm Sewer Cleaner. The aforesaid vehicle is now in service.
- The 1988 Mobile Sweeper was sold to Peterson Landscaping who bid \$4,502.00.

DPW REPORT September 6, 2004

- Some village streets have been swept.
- Cleaned tops of catch basins as needed.
- Cleaned some storm sewer catch basins in Village with new storm sewer cleaner.
- Picked up brush and leaves put out to curbs.
- Lance did Code as needed.
- Cut grass as needed.
- Jeff did water backflow tests at new Best Western Motel on Rte. 417.
- Did water, sanitary sewer and storm sewer locates as needed.
- Assisted the town with hauling gravel for resurfacing of Morgan Hollow Road.
- Sealed parking lot at the Village Municipal Bldg. and prepared for parking lines to be put down.
- Richard Peck Construction started the curbing and storm sewer upgrade on Maple Avenue.
- Talked with Flygt, H&K Services, Total Control and Stayer Electric reference to bids for sewer Lift Station #2 Upgrades. Items for project have been ordered by all. Project should start sometime in September.
- Eight Water Hydrants and shutoff valves were installed.
- Village Water Storage Tank was inspected and everything looks real good. Recommendation was made to get outside of tank cleaned. Will request Village to give permission to rent a man-lift so we can get outside of tank cleaned.
- New light poles on Main Street were repainted by contractor who installed them last year. Put flagpoles, American flags and banner poles back up on the light poles.
- Water test results

DPW REPORT October 4, 2004

- Some village streets were swept.
- Cleaned tops of catch basins as needed.
- Cleaned some storm sewer catch basins in Village with new storm sewer cleaner.
- Picked up brush and leaves put out to curbs.
- Lance did Code as needed.
- Jeff did water backflow tests at new Best Western Motel and Richter Center at SBU.
- Cut grass as needed.
- Did water, sanitary sewer and storm sewer locates as needed
- Put down parking lines and marked off handicap parking area and walkway in parking lot at the Village Municipal Bldg.
- Richard Peck Construction completed the curbing and storm sewer upgrade on the south side of Maple Avenue and the north side is almost complete.
- Water Meters in village were read.
- Assisted the Town with sewer machine to unplug a couple of sluice pipes
- Town of Allegany hauled and assisted in spreading blacktop grindings on roadway leading to and around the Village Water Storage Tank.
- Fixed parking lot at Village Tasty Treats where State Construction Project did not take care of when they left last fall.
- Shut water off at Village/Town Park on Union Street for the winter months.
- Installed water meters at Grandusky properties on Main Street.
- Fixed broken water line on North Second Street.
- Replaced Six Main Street light bulbs on Main Street.
-

DPW REPORT October 4, 2004 Continued

- Talked with Flygt, H&K Services, Total Control and Stayer Electric reference to bids for sewer Lift Station #2 Upgrades. Items for project have been ordered by all. Project should start sometime in October.
- Patched pot holes and skid patched areas on Union Street.
- Patched pot holes in various areas of Village.
- Resurfaced roadways at St. Mary's, St. John's and St. Joe's.
- Stayre Electric installed Emergency Lighting in areas of Municipal Building where they were needed.

DPW REPORT November 1, 2004

- Some village streets were swept.
- Cleaned tops of catch basins as needed.
- Picked up brush and leaves put out to curbs.
- Lance did Code as needed.
- Cut grass as needed.
- Did water, sanitary sewer and storm sewer locates as needed
- Richard Peck Construction completed the curbing and storm sewer upgrade on Maple Avenue. School to finish small section when big trucks are done in area.
- Fixed two broken water lines on Maple Avenue.
- Talked with Flygt, H&K Services, Total Control and Stayer Electric reference to bids for sewer Lift Station #2 Upgrades. Items for project have been ordered by all. Project should start sometime near week of November 15th.
- Started flushing sewers (Fall all flush)
- Put down top soil in areas where fire hydrants were replaced.
- Dug two holes in storm water drainage area on East Main Street and filled them in with oversize rocks to try and keep the area drier so work can be done there.
- Started hauling street sand to prepare for winter months.
- Patched holes in streets with blacktop.
- Cleaned up wood from five dangerous trees on North Second Street that Niagara Mohawk cut down.
- Superintendent Papasergi, Clerk Flynn and Jeff Lauser attended a meeting in Salamanca reference to GIS. GIS in Village will start being implemented beginning Monday, November 08, 2004 as part of a grant we are participating in.

DPW REPORT December 6, 2004

- Some village streets were swept.
- Cleaned tops of catch basins as needed.
- Picked up brush and leaves put out to curbs.
- Lance did Code as needed – all sidewalk replacements were inspected and approved.
- Cut grass as needed.
- Did water, sanitary sewer and storm sewer locates as needed
- Upgrade at Sewer Lift Station #2 is 95% complete –just waiting on Total Control to add a noise reducer. So far everything has been working great. – Recently noticed a problem with one of the discharge pipes – pipe has a crack in same and needs to be replaced. Currently in process of getting estimate to replace the discharge pipe and inspect and or replace others if needed.
- Hauled street sand and mixed with salt to prepare for winter months.
- Met with Fries Tree Service reference to getting estimates on removing stumps of previously cut down trees and to remove tree by Finch's on Third Street.
- Collected information for GIS in Village per grant we are participating in.
- Prepared Vehicles for winter projects.
- Put sander on truck – sand blasted chute and back of sander and repainted it.
- Did needed repairs on snow plows – all checked over and ready for use.
- Mower taken off trackless and snow tires and plow was put on same, now ready for sidewalk plowing.
- Took down American Flags off light poles on Main Street and changed some light bulbs that were out.
- Put up Christmas Wreaths on Main Street light poles.
- Decorated Municipal Building for Christmas in Allegany and the Holiday Season.

DPW REPORT December 6, 2004 Continued

- Electric eyes were put on Main Street Electrical Boxes by Stayer Electric to control Main Street light pole receptacles. Wreaths now come on at night and go off during the day.
- Met with Eric Wohlers from Catt. Co. Health Dept. and Town highway Superintendent reference to Annual Water Inspections.
- Hooked up new water service for Fire commissioners newly purchased building at the corner of First and Main (the old Mobil Station).
- Replaced meter that was hit by lightning at Water Well House #3 on Union Street.

DPW REPORT January 10, 2005

- Sanded streets and plowed snow from streets and sidewalks as needed.
- Cleaned tops of catch basins as needed.
- Picked up Xmas trees put out to curbs.
- Lance did Code as needed
- Did water, sanitary sewer and storm sewer locates as needed
- Still in the process of getting estimate to replace the discharge pipe and inspect and or replace others if needed at Sewer Lift Station #2.
- Put up fencing around storm water drainage area on East Main Street.
- Have been upgrading Water Well House #3 cla-val.
- Heater at Water Well House #1 went bad causing waterlines leading to fluoride and chlorinator units to freeze up. Heater has been replaced. Currently replacing other items damaged and upgrading Water Well House #1 so it will be able to go back in service hopefully sometime this year.
- Read water meters for quarterly billing.
- Flushed sewers. Did all flush on flats and monthly flush on hill.
- Unclogged a main sewer line at St Bona's.