



Carmina ♦ Wood ♦ Morris^{DPC}

487 Main Street Suite 500 Buffalo, New York 14203 P: 716.842.3165 F: 716.842.0263 W: cwm-ae.com

September 20, 2018

Mr. Nicholas Dobmeier
Clark Patterson Lee
130 South Union Street, Suite 4
Olean, NY 14760

Re: **Proposed Retail Plaza
3139 West State Street
Allegany, NY 14760**

Dear Mr. Dobmeier:

On behalf of our client, Ellicott Development Company, please find enclosed the following REVISED documents:

revised civil plans

We offer the following responses to the CPL comment letter dated September 20, 2018:

1. Roof areas are accounted for under the impervious cover in the HydroCAD report.
2. Per our phone conversation on 9/20/18, the 100-yr flood boundary hatching has been removed as the established BFE of 1408 is not located on our site.
3. Temporary crosswalk striping has been added to sheet MPT-1.

C-001 – Demolition and Erosion Control Plan:

- The referenced note has been amended to indicate pipe removal rather than abandonment.

C-002 – Erosion Control Notes:

- New detail has been added for silt sock installation across pavement areas.

C-300 – Drainage Plan:

- Note has been added indicating that existing storm pipe size is unknown and that contractor is to field verify.

Proposed Retail Plaza
3139 West State Street
Allegany, NY

If you should have any questions regarding this letter, please contact me at (716) 842-3165 x119. Thank you.

Sincerely,
Carmina Wood Morris, D.P.C.

A handwritten signature in black ink, appearing to read "Anthony J. Pandolfe". The signature is fluid and cursive, with the first name "Anthony" and last name "Pandolfe" clearly distinguishable.

Anthony J. Pandolfe, EIT | Engineering