

## DPW REPORT FOR THE MONTH OF FEBRUARY 2016

- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Shoveled snow from around fire hydrants throughout village.
- Cleaned out floor drains at DPW Building
- Cleaned police and DPW vehicles.
- Finished doing backflow testing in the town and in village - only have a few that need to be fixed so that they can be tested again.
- Talked with representatives at J&J Equipment in Syracuse. They advised they should be done with refurbishing the Street Sweeper Vac Com towards the first week of March.
- Floater assembly for front plow was installed on the new Wacker Loader (sidewalk plow) as it was not put on when we received the machine.
- Finished picking up Christmas trees that were put out in subways by area residents.
- Continued remodeling the PD area of the Municipal Building and adding an Office area for the Mayor. Work is being performed by PD and DPW Staff under the direction of Sgt. McGraw and should be completed towards the beginning of March. Compliments to Sgt. McGraw and staff they are doing a great job.
- Have been working on getting prices on upcoming projects - Water Main loop from North First to North Second and Water Main Meter Pits to be put on water lines going outside the village. Met with engineer for meter pit project and with Catt Co Health Department, engineer, surveyor, and property owner needed for right of way for water loop project.
- Finished cleaning and videoing of Sewer Mains with Sewer Specialties' on Union Street, East Main Street from South Seventh easterly to Village line, West Main Street, North and South First Street and Fifth Street. Sewer Specialties' has finished the Engineering Planning Grant (EPG) project that was granted last year. Found areas in some sewer mains where previous contractors broke tiles around new sewer service lines or sewer services lines that were abandoned. Approval has been given by Board to have these areas repaired with estimated cost being approximately \$25,000.00. Sewer Specialties' will start repairs in the beginning of March.
- Gathering information and met with engineer, attorney and others reference to letter received from City Mayor pertaining to their Sewer Project.