

DPW REPORT FOR THE MONTH OF JANUARY 2014

- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Lance attended Code School in Buffalo NY.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Still in the process of comparing chlorine and fluoride readings from new analyzers to manual chlorine fluoride readings.
- Water Well House No 1 was put back in service.
- Finished picking up Christmas Trees that were put out to curbs by village residents.
- Continued sealing up areas around the front and back shop buildings where an excessive amount of heat loss is occurring due to old age of buildings.
- Heater located in one side of Water Well House No. 2 quit working and as a result water lines, eye washing unit and chlorine pump inside building froze up. A new heater was installed by Stayer and DPW Staff replaced the water lines and chlorine pump. Will order new eye wash unit. Well is back in service.
- Heat thermostat quit working in the Water Pressure Building no frozen lines - thermostat was replaced on heater.
- In the process of adding a locked storage area in back shop so that tools and other items can be more properly secured.
- Replaced old tool box that had damaged doors and sliders that no longer worked. Also started replacing other bins and slider doors that store various assortments of nuts, bolts, electrical fuses, cotter pins etc... as they were over twenty years old and some could hardly be opened. Tool box will be locked and other bins will be placed in new lock up room.
- Replaced several bottoms of meters throughout village that had frozen up during cold spells that have been occurring.

- New grates were ordered for floor drains in back shop. Estimate given was \$300.00 less than quoted due to quote not including grates that were load banded to strengthen for heavy trucks. Total for grates ordered was \$2,250.00.

DPW REPORT FOR THE MONTH OF FEBRUARY 2014

- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Still in the process of comparing chlorine and fluoride readings from new analyzers to manual chlorine fluoride readings.
- Finished building locked storage area in back shop so that tools and other items can be more properly secured.
- Replaced several bottoms of meters throughout village that had frozen up during cold spells that have been occurring.
- Request to shut water off due to a water line break inside 50 Harriet Street. Water service shutoff was located inside building. Attempted to shut water off with no success - dug up access to shutoff still could not get water shut off. Dug out by roadway and installed a new water service shut off. Owner to remove shut off inside building and reconnect to waterline.
- Assisted Cattaraugus, Cuba, Olean, Franklinville and Wellsville - Thaw machine used to unthaw water service lines at various customers in their areas.
- Unthawed a frozen water service line on two occasions at 102 West Main Street - assisted by Olean City.
- Repaired a water service shutoff at 170 North Second Street.
- Started doing back flow annual testing in the Town.
- Hauled sand and mixed sand and salt to continue road surface treatment during the winter months.
- Dug up water service line at Water Well House Number Two - replaced the valve stem casing.
- Put cold patch in potholes throughout village.

- Took down Christmas decorations on Main Street light poles and in front of Santa House.
- Took down Christmas decorations that were on Municipal Building and around Santa House.
- Met with Richard Gray from Roy Teitsworth Inc. to get appraisals on DPW Vehicles and Equipment.
- Worked on 2014 - 2015 Fiscal Budgets.

DPW REPORT FOR THE MONTH OF MARCH 2014

- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Lance started conducting Fire Inspections at businesses in the Village.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Still in the process of comparing chlorine and fluoride readings from new analyzers to manual chlorine fluoride readings.
- Water meters were read for water/sewer quarterly billing.
- Replaced more bottoms of meters that had frozen up do to cold spells that have been occurring.
- Unthawed a frozen water service line at 102 West Main Street - assisted by Olean City. Owner was advised to keep water running.
- Disposed of old broken tools and started restocking with new tools needed to be used for projects.
- Continued doing back flow annual testing in the Town.
- Put cold patch in potholes throughout village.
- Unclogged and cleaned out a sewer line on West Main Street near the Allegany Car Wash assisted by the City of Olean.
- Ordered a new Dump Truck with a Stainless Steel Multi-Purpose Box and Plow and ordered/scheduled to have a Multi-Purpose Stainless Steel Box and Plow to be put on the 2000 International Dump.
- Unclogged a sewer main in the area between North Second and North Third Street.
- Started sweeping streets with street sweeper. All streets have been swept except for Sixth Street, Oak Street, Woodland Drive and Circle Oak.

- Lance, Frank, Tony and Tim all attended a water training course at the Firemen's Community Center in Allegany.
- Submitted Final requests on 2014 - 2015 Fiscal Budgets.

DPW REPORT FOR THE MONTH OF APRIL 2014

- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Picked up weeds, leaves, tree limbs and other yard waste that was put out to curbs by village residents. Last day to put debris out will be May 21st.
- Lance did Code as needed - see Code Enforcement Blotter.
- Lance finished Fire Inspections at businesses in the Village.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Put cold patch in potholes throughout village.
- Raked out sod that was lying in subways throughout village as a result of snowplowing roadways and sidewalks during winter months
- Started flushing sewer mains in Village.
- Dug and repaired water service shutoff at 170 North Second.
- Repaired water service shutoff at 2 Pierce Drive.
- Finished sweeping streets with street sweeper. All village streets have been swept.
- Members of the Allegany Fire Department washed down subways on Main Street in areas between First Street and section just east of Fifth Street. Village and Town had a member out to sweep up debris hosed into street.
- Repaired water meters that were not working properly at various residences and/or businesses in need of same.

DPW REPORT FOR THE MONTH OF MAY 2014

- Picked up weeds, leaves, tree limbs and other yard waste that was put out to curbs by village residents. Last day for pick up was May 21st .
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Put cold patch in potholes throughout village.
- Swept and hauled away sand out of subways in village.
- Swept sand that was swept into street from subways off streets with street sweeper. Town assisted with their street sweeper.
- Started flushing sewer mains in Village.
- Ran sewer root cutter through sewer lines on Chestnut, Harriet, and North Fourth Streets and area between North Fourth and North Third Street.
- Put up American Flags on Main Street light poles.
- Put up and took down Business Association Community Garage Sale Banner on West Main Street.
- Started cleaning out storm sewer catch basins with Street Sweeper Vac/Com.
- Repaired a storm sewer catch basin in the area in front of 97 and 103 North First Street.

DPW REPORT FOR THE MONTH OF JUNE 2014

- Cut grass as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Water meters were read for water/sewer quarterly billing.
- Continued cleaning out storm sewer catch basins with Street Sweeper Vac/Com.
- Started putting down topsoil and seeded same in subways and other areas throughout village where damage occurred due to snowplowing roadways and/or sidewalks during winter months.
- Started grinding out pot holes and/or bad spots in areas on roadways in need of same. Put tack coat down and patched areas grinded out with hot blacktop. Most of the roadways in the flats are done, will continue to finish up on flats and then start on hill areas. Assisted by Catt Co DPW who furnished an operator and skid steer grinder.
- Started crack filling cracks in roadways and crack filled areas that have been patched.
- Worked on getting the Police / EMT building at Firemen's Park ready for Old Home Week Activities.
- Started painting and putting down glass beads on crosswalks in village - Finished flats will continue on hill area.
- Put up and took down temporary No Parking Signs on Pine Street, Elm Street, North First Street and in areas of the Fire Station in preparation for Firemen's Old Home Week Activities.
- Put out and picked up detour signs in areas on Main Street Route 417, Union Street and First Street/ Five Mile for established detours for parades conducted for annual Old Home Week Activities.
- Flushed Water Mains on First, Pine, Elm, Second, Third, Fourth, Maple Ave and Fifth Streets.

- Worked on getting DPW and Police vehicles cleaned inside and out.
- Weed whacked areas around Municipal Building, DPW Shop, and Water and Sewer facilities.
- Chris Short from EMCOR is looking into prices for replacement of the sewage flow monitoring device that monitors Village/Town sewage that is leaving Sewer Lift Station #2 and going to City of Olean.

DPW REPORT FOR THE MONTH OF JULY 2014

- Cut grass as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Continued cleaning out storm sewer catch basins with Street Sweeper Vac/Com.
- Flushed sewer mains throughout village.
- Fixed the water service shutoff at the corner of Jefferson and Nolan Drive.
- Dug up and replaced two hydrants on Jefferson Street and inserted new shutoff valves on hydrants
- Replaced and/or added new water main valves on Jefferson Street.
- Dug up and replaced a fire hydrant on Devereux Drive and inserted a new shutoff valve on hydrant.
- Put down topsoil and seeded same in areas where hydrants and valves were replaced.
- Picked up tree branches and took out a tree stump on East Main Street from a tree that was damaged due to it being struck by a motor vehicle.
- Took out No Parking Signs on North Second Street, Maple Avenue and South Seventh Street - signs were thinned out in these areas.
- Took down No Parking Signs on the south side of Harriet Street and put up new No Parking Signs on the north side of Harriet Street.
- Started to put up No Parking Signs per new Local Law. Signs were put up on the north side of Oak Street, both sides of Sherwood Drive in the area between North Fifth Street and Williams Street on North Seventh Street.
- Dug up and replaced a water service that was leaking on North Third Street.
- Frank and Tony went to Watertown to look over new truck that was recently ordered - checked to make sure truck was built to specs.

- The 2001 International Dump Truck was returned from Henderson Truck Equipment after a new stainless steel multipurpose box was installed on same.
- Four trees that died due to harsh winter on West Main Street were dug up and removed.
- Extended hydrants in need of same on Williams Street and White Oak Drive.
- Put in a handicap ramp at the front DPW Shop.
- Swept Streets with street sweeper.
- Mowed and removed weeds around Water Tank and Sewer Lift Station Two.
- Swept and cleaned out area around Municipal Building.
- Removed weeds from brick subway areas on Main Street.

DPW REPORT FOR THE MONTH OF AUGUST 2014

- Cut grass as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Dug up and replaced a water service shutoff at 62 North Third Street.
- Dug up and replaced a hydrant on Jefferson Street and inserted a new shutoff valve on hydrant.
- Finished grinding out and replacing hot patch on roadways in areas of village in need of same.
- Finished blowing out and filling in cracks on village roadways with crack filling.
- Mayor Lamberson and DPW Superintendent Papasergi met with Tom McElheny of Clark Patterson Engineering to discuss getting back shop building safe so vehicles could be put back in building. Also met with contractors to get quotes for work to be done.
- Dug up and replaced a fire hydrant and shutoff valve and inserted a new water main shutoff on Devereux Drive near Pierce Drive.
- Dug up and replaced a hydrant and inserted a new shutoff valve on the hydrant on Pierce Drive.
- Dug up and replaced the water main valve at the water main line for Devereux Drive at Nolan Drive.
- Dug up and replaced the water main valve at the water main line for White Oak Drive at Jefferson Drive.
- Put down topsoil and seeded same in grass areas where hydrants and valves were replaced.
- Put black top down in areas of roadways where water main valves were replaced.
- The new 2014 International Dump Truck came in and was put in service. Need to add radio and get vehicle lettered.

DPW REPORT FOR THE MONTH OF SEPTEMBER 2014

- Cut grass as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Mayor Lamberson and DPW Superintendent Papasergi met with Tom McElheny of Clark Patterson Engineering to discuss getting back shop building safe so vehicles could be put back in building. Also met with contractors to get quotes for work to be done.
- Put black top down in areas of roadways where water main valves and/or water services were replaced.
- Water meters were read for water/sewer quarterly billing.
- Picked up large tree branches that came down throughout the Village in result of a storm that passed through our area. Most tree limb falling occurred on the hill area of Village.
- Crew received training on the new stainless steel multipurpose boxes that were recently installed on the dump trucks.
- Repaired and resurfaced the following roads with fiber seal and limestone:
 - All of Sherwood Drive
 - All of Williams Street
 - All of Clarence Street
 - All of Jefferson Drive
 - All of Devereux Drive
 - All of Pierce Drive
 - All of Spruce Street
 - Harriet Street from N 5th Street westerly to Spruce Street
 - Chestnut Street from N 4th Street southerly to N 2nd Street
 - Oak Street from N 7th Street easterly to Bona Church Parking Lot
 - North First Street from Rte. 417 northerly to Elm Street
 - North Seventh Street from Rte. 417 northerly to Nolan Drive
 - South Seventh Street from Rte. 417 southerly to endAssistance was provided by Town of Allegany, Town of Olean and City of Olean.

- Put up Electrical boxes on light poles on Main Street for the annual BONAGANY Event.
- Put out and picked up street road detour signs designating detour prior to and after the Annual BONAGANY Event.
- Cleaned up Main Street area after the Annual BONAGANY Event. Assisted by Town.

DPW REPORT FOR THE MONTH OF OCTOBER 2014

- Cut grass as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Staff cleaned out areas around the northern wall, eastern wall and front south east wall of the back shop and removed the bathroom to prepare areas for reconstruction work to be done as approved by the village board. Superintendent feels village taxpayers would be better served if board would consider the tear down of old building and reconstruction of a new building for the quoted price of \$360,000.00.
- Swept gravel off of the following roads that were recently resurfaced with fiber seal and limestone:
 - All of Sherwood Drive
 - All of Williams Street
 - All of Clarence Street
 - All of Jefferson Drive
 - All of Devereux Drive
 - All of Pierce Drive
 - All of Spruce Street
 - Harriet Street from N 5th Street westerly to Spruce Street
 - Chestnut Street from N 4th Street southerly to N 2nd Street
 - Oak Street from N 7th Street easterly to Bona Church Parking Lot
 - North First Street from Rte. 417 northerly to Elm Street
 - North Seventh Street from Rte. 417 northerly to Nolan Drive
 - South Seventh Street from Rte. 417 southerly to end
- Assisted DePuy Electric with converting Main Street Light Poles and putting up new led lights to improve the lighting in the Main Street business district area.
- Assisted DePuy Electric with fixing one of the Main Street Lighting Electric Service Boxes that was struck by an unknown vehicle in the area of Graffiti Pizza & More. Also fixed the Electric service anchor located on the side of the Rays Carpet Building which loosened up from the cable across Main Street which holds banners.
- Started picking up weeds, leaves, tree limbs and other yard waste that was put out to curbs by village residents.

- Worked on equipment in preparation for winter snow and ice removal maintenance.
- The following village DPW Equipment was put out to bid:
 - 10 Foot Viking Full Trip Reversible Plow
 - 11 Foot Viking Trip Edge Reversible Plow
 - 250 Gallon Fuel Tank
 - 1995 Lancaster Tanks 500 Gallon Fuel Tank with Secondary Containment and Shed Attachment
 - 1992 International Dump Truck - Automatic Transmission Diesel 6 Cylinder with 31,848 Miles
 - 1998 Ford F 80 Dump Truck Diesel 6 Cylinder with 27,006 Miles
 - 2010 Stainless Steel Truck Engine Powered Hydraulically Controlled All Purpose Conveyer Type Hopper Body with Spreader for Salt, Sand, Chlorides, Mixtures and Chips

DPW REPORT FOR THE MONTH OF NOVEMBER 2014

- Picked up weeds, leaves, tree limbs and other yard waste that was put out to curbs by village residents. Last day of pickup was November 20th.
- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Hauled sand to be mixed with salt for road surface treatment during the winter months.
- Mixed sand and salt for road surface treatment during the winter months.
- Worked on equipment in preparation for winter snow and ice removal maintenance.
- Started working on remodeling of the DPW front shop area. Superintendent feels village taxpayers would be better served if board would consider the tear down of old back shop building eliminating front shop area and reconstruction of a new building for the quoted price of \$360,000.00.
- Took down flags from Main Street light poles.
- Put up Christmas decorations on Main Street light poles in preparation for Christmas in Allegany Event.
- Put up Banners on East Main Street.
- Put up Christmas decorations on Municipal Building in preparation for Christmas in Allegany Event.
- The following village DPW Equipment was put out to bid and sold:
 - 10 Foot Viking Full Trip Reversible Plow
 - 11 Foot Viking Trip Edge Reversible Plow
 - 250 Gallon Fuel Tank
 - 1995 Lancaster Tanks 500 Gallon Fuel Tank with Secondary Containment and Shed Attachment

1992 International Dump Truck - Automatic Transmission Diesel 6 Cylinder with 31,848 Miles

1998 Ford F 80 Dump Truck Diesel 6 Cylinder with 27,006 Miles

2010 Stainless Steel Truck Engine Powered Hydraulically Controlled All Purpose Conveyer Type Hopper Body with Spreader for Salt, Sand, Chlorides, Mixtures and Chips

DPW REPORT FOR THE MONTH OF DECEMBER 2014

- Sanded and plowed snow from streets and lots and plowed snow from sidewalks as needed.
- Lance did Code as needed - see Code Enforcement Blotter.
- Did water, sanitary sewer and storm sewer locates as needed.
- Cleaned off tops of Storm Sewer Catch Basins as needed.
- Worked on equipment in preparation for winter snow and ice removal maintenance.
- Worked on backflow testing at areas in the town water system that require same.
- Water meters were read for water/sewer quarterly billing.
- Started putting insulation strips along bottom areas of Back DPW Metal Building that had partial cement was installed recently by Duggan and Duggan. The two overhead doors that were scheduled to be raised by Duggan and Duggan were raised. Trucks go in building better height wise but there is still an issue width wise - have 11 foot plows on trucks and door opening is only 12 feet.
- Continued working on remodeling of the DPW front shop area. Superintendent feels village taxpayers would be better served if board would consider the tear down of old back shop metal building eliminating front shop area and reconstruction of a new building for the quoted price of \$360,000.00.
- Fixed a broken water service connection in front of the Dietz residence on Jefferson Avenue.