

VILLAGE OF ALLEGANY, NEW YORK
LOCAL LAW NO. 1 – 1997

A LOCAL LAW TO AMEND CERTAIN SECTION OF LOCAL LAW 5 – 1984 ENTITLED
“A LOCAL LAW REGULATING THE USE OF SEWERS, PUBLIC AND PRIVATE, AND
REGULATING SEWAGE DISPOSAL AND DISCHARGE OF WASTE INTO THE PUBLIC
SEWER SYSTEM, COMPLYING WITH CONTRACTUAL ARRANGEMENTS BETWEEN
THE VILLAGE OF ALLEGANY, NEW YORK AND THE CITY OF OLEAN, NEW YORK.”

BE IT ENACTED BY THE VILLAGE BOARD OF THE VILLAGE OF ALLEGANY, NEW YORK
AS FOLLOWS:

SECTION 1. Section 12 “TAPPING OF PUBLIC SEWERS” of Local Law No. 5 – 1984 is amended to read as follows:

Section 12. TAPPING OF PUBLIC SEWERS.

No tapping of the public sewers shall be permitted, except 4-inch branch into 8-inch sewer and 6-inch branch into 10-inch or larger sewer, and in each specific case only by permission of the superintendent. Making of the tap shall be under the supervision of the superintendent. Taps may be made directly into an existing manhole on approval of the superintendent only. Such taps must be made a minimum of twelve (12) inches off the bottom.

SECTION 2. Section 13 “BUILDING SEWER PIPE SPECIFICATIONS” of Local Law No. 5 – 1984 is amended to read as follows:

Section 13. BUILDING SEWER PIPE SPECIFICATIONS

The building sewer shall be scheduled 40 or heavier plastic pipe (PVC or ABS) service weight cast iron pipe or extra heavy cast iron pipe. Asbestos cement pipe is not allowed. Joints shall be tight and water proof. Building sewer pipe of cast iron shall have a maximum length of ten (10) feet between joints, or shall meet requirements of the state inspection code applicable to plumbing.

SECTION 3. Subdivision of (d) of Section 18 “JOINTS AND CONNECTION” of Local Law 5 – 1984 is deleted in its entirety.

SECTION 4. Subdivision of (d) of Section 24 "DESIGN OF SEWER EXTENSION; PLAN AND SPECIFICATIONS" of Local Law 5 – 1984 is amended to read as follows:

Section 24. DESIGN OF SEWER EXTENSIONS; PLANS AND SPECIFICATIONS.

(d) Manholes shall be constructed at all changes in slope or alignment or at intervals not exceeding three hundred (300) linear feet. The manholes shall be constructed with a poured three thousand (3,000) PSI concrete base twelve (12) inches thick, steel trowelled concrete or mortar bench walls and inverts, and precast 4-foot diameter concrete manhole barrel sections with concentric tapered top section, as specified by ASTM C-478. The manhole frame and cover shall be the standard design of the Village and shall be set with no less than two (2) courses of brick underneath to allow for later adjustment in elevation. All joints shall be sealed against infiltration. No manholes shall be constructed without stops or ladder rungs.

SECTION 5. This local law shall take effect in accordance with the provisions of Section 27 of The Municipal Home Rule Law, upon filing in the Office of Secretary of State of the State of New York.